




NOTES

- 1. The variable dimension indicated for the height of step for step mitered pipes shall conform to the manufacturers recommendations unless specified differently on the plans or in the Special Provisions.
- 2. Reinforcing steel shall have 1 1/2" min. clear cover to all concrete surfaces.
- 3. Headwalls for concrete culvert pipe may omit anchor bolt attachment.
- 4. When steel pipe safety bars ar used, headwall thickness shall be increased

STRUCTURAL PLATE PIPE ARCHES AND UNDERPASSES







ANCHOR BOLT DETAIL



EXPIRES JULY I, 2007

SHEET 1 OF 1 SHEET

APPROVED FOR PUBLICATION

Harold J. Peterfeso

06-01-06



NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE.
THE ORIGINAL, SIGNED BY THE ENGINEER AND APPROVED FOR PUBLICATION, IS KEPT ON FILE
AT THE WASHINGTON STATE DEPARTMENT OF TRANSPORTATION. A COPY MAY BE OBTAINED UPON REQUEST.